



WEST COVINA FIRE DEPARTMENT



FIRE LANE IDENTIFICATION


Fire Lane - No Parking Sign (Mandatory)



Notes:

- Signs shall be in accordance with Caltrans/FHWA standard [R26F]
- Signs shall include appropriate CVC section [22500.1]
- Sign shall be adjacent/visible from the designated fire lane
- Spaced at maximum intervals of 50ft on center or fraction thereof
- Signs shall be mounted 7ft above grade
- Lettering shall not be less than 1" in height

Fire Lane – Curb/No Curb Painting (with above sign)



AREAS WITH CURB:

- Entire curb shall be painted red [two coats]
- White lettering – “Fire Lane – No Parking” [two coats]
- Lettering height – minimum of 4”
- Lettering to be on top of designated curbing
- Spaced at maximum intervals of 30’ on center or fraction thereof

AREAS WITH NO CURB:

- Designated areas shall be painted red [two coats]
- White lettering – “Fire Lane – No Parking” [two coats]
- Lettering height – minimum of 6”
- Spaced at maximum intervals of 30’ on center or fraction thereof