




WEST COVINA FIRE DEPARTMENT
Fire Prevention Bureau
(Emergency Responder Gate Access)

- WCMC Chapter 10 - Section 503.5.1 and Section 503.6 of the Adopted Fire Codes are hereby amended to read as follows:
 - Section 503.5.1 and Section 503.6 - Security Gates and Building Security Access.
 - All security gates shall be operable by the fire department by way of an emergency entry system approved by the fire chief.
 - All security access systems on building entrances or openings used for emergency access shall be operated by the Fire Department by way of a card reader, which will accept a Fire Department master key card. At the discretion of the Fire Chief or Fire Code Official, an approved **key box** or a radio operated control system may be required as a substitute, or in addition to, the emergency key card entry system.

****AS OF 04/14/21 GATE CARD READERS WILL NO LONGER BE USED IN WEST COVINA****

To order a Knox Key Switch, please visit www.knoxbox.com



Gate & Key Switches

Gate & Key Switches

Model: 3512

MSRP: ~~\$352~~ ⓘ

Price: \$229

1. Lock & Mounting Type

- Dual Lock on Plate

2. Switch Type

- Toggle (2-Position)
- Hold to Activate (Momentary)

3. Signals

- One Signal per Lock (SPDT)
- Two Simultaneous Signals per Lock (DPDT)